



BURNERLANCES ..-HA...

00-W101-0Z-E

LICENCE  
to use the "DIN Geprüft" mark

27-01-12



# CERTIFICATE

The company

**Fluidics Instruments BV**  
Dillenburgstraat 34  
5652 AP EINDHOVEN  
HOLLAND

hereby receives the confirmation that the product/s

**Safety shut-off devices for combustion plants**

of the type

**12 HA-, 24 HA-, 32 HA-, 40 HA-**

conforms to

**DIN EN ISO 23553-1:2009-10**  
Certification scheme Safety shut-off devices for combustion plants using liquid fuels  
(Edition: 2010-06)

and is granted the licence to use the mark



in conjunction with the Registration No. below.

**Registration No.: 5S161**

**This Certificate is valid until 2016-03-31.**

See annex for further information.  
DIN CERTCO Gesellschaft für  
Konformitätsbewertung mbH  
Alboinstraße 56, 12103 Berlin



2011-10-05  
Dipl.-Ing. Peter Suxdorf  
- Managing Director -



LICENCE  
to use the "DIN Geprüft" mark

27-01-12

Page 1 of 1

**Annex**

to the Certificate with Registration No. 5S161, dated 2011-10-05

**Technical data**

Construction: Safety shut-off devices, trip device  
Type: 12 HA-, 24 HA-, 32 HA-, 40 HA-

Connection: entry G 1/4" to G 3/4" - output/exit Jet- Stopvalve  
Medium: fuel oil EL, M, S  
Max. operating overpressure: 20 bar to 40 bar  
Max. working temperature: 0 °C to +60 °C  
Max. medium temperature: 0 °C to +140 °C  
Nominal pressure: PN 40

**Testing laboratory / Inspection body**

TÜV Rheinland  
Energie und Umwelt GmbH  
Test Centre for  
Energy Appliances  
Am Grauen Stein  
51105 Köln

**Test report(s)**

V57 2006 A2 dated 2006-05-10  
Ü V57 2006 A2 dated 2008-04-08 (432/21209286)  
Ü V57 2006 A2 dated 2010-04-17 (432/21209286)  
V81 2011 T2 dated 2011-09-20  
Data sheet dated 2011-09-29